



STATE OF TENNESSEE  
Tennessee Department of Correction, Bledsoe County Correctional Complex

## INVITATION TO BID # 32901-11492 FOR DOORS AND FRAMES, BCCX Site 1, TDOC

### ITB # 32910-11492 Questions and Comments

#### 1. State responses to questions and comments in the table below amend and clarify this ITB.

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

QUESTION / COMMENT	STATE RESPONSE
Please confirm that this is a furnish only job?	This is a furnish material only job
Can you specify which glazing type should be provided? There are multiple "types" provided, but nothing specified.	Security Grade #2 glazing, no less than 9/16 inches thick. No tinting of the glazing
What hardware set are we to provide? There are multiple hardware sets provided in the 'Door Hardware Specs', but they do not match the 'Hardware Set A' shown in the drawing provided in the 'Guild Door Specs'. Please state whether we should use 'Hardware Set A' or one of the sets in the Door Hardware Specs.	Hardware set A is the hardware to be used